

# SSC

## ● Standards

- ARI 550-90 ( American Refrigeration Institute )
- ASHRAE 90.1 ( American Society for Heating, Refrigeration & Air Conditioning Engineers Incorporation )

Application scope:			شرایط کارکرد:	
Item			Unit	Value
Outlet temperature of cold water			°C	+5 ~ +10
Condenser	Water-cooled	Inlet temperature of cooling water	°C	+19 ~ +33
	Air-cooled	Dry bulb temperature of intake air	°C	+21 ~ +43

## Models Symbol

## شماره مشخصه مدل ها

